

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20191817
Address: 1200 NE GOSHEN DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, July 02, 2020
Inspected By: Khanh Nguyen
Expiration Date: 8/3/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, July 02, 2020

Corrective Action Required:

1	Misc	-Deck: handrail must extend to top riser **Either install an un-spliced handrail or install handrail support bracket at the spliced joint. FYI: code requires that the handrail must be able to handle 200 lbs of concentrate force
---	------	--