CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191624

Address: 2700 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Electrical Khanh Nguyen Partial Monday, July 06, 2020

Inspection - Commercial

Partial Correction:

1 Misc -UNDERGROUND RACEWAYS TO LIGHT POLES-OK: UE FROM BUILDING TO NW

AND SE LP;

-UE FROM TRANSFORMER TO MDP OK

Comments: