

Inspection Summary

Permit #: PRCOM20191159, Building Permit - Commercial
SUMMIT WAVES - WAVE POOL
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Field Services	Steve Robbins	Temporary C of O	Monday, July 06, 2020

Corrective Action Required

- 1 It has now been verified that the water service line has been installed by the water dept. and it is a 2" copper line from the main to the meter. There was a change to the plans. I now have a new list of items that need to be taken care of.
 1. As-builds for the detention basin.
 2. Public fire hydrant that was installed needs to be turned so it is facing Jefferson St.
 3. Hydrant needs to be painted yellow. We do not accept Red.
 4. Please lower valve lid so it is flush with the ground.
 5. The outlet structure for the detention basin has mud inside of it and it does not drain to the swale that is on Jefferson St. We are having standing water.

Comments: