

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRLD20200437  
Address: 2025 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John DiMauro	Partial	Tuesday, July 07, 2020

Corrective Action Required:

3	Misc	There are still areas on site that need erosion control devices installed according to the approved plans Phase A sheet C405.
		Install the remainder of the silt fence and establish the diversion berms.

**Comments:**