

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Air Test	John DiMauro	Passed	Thursday, June 18, 2020

Informational:

1	Misc	John DiMauro 06/18/2020 2:30 PM
---	------	---------------------------------

I observed the sanitary sewer air test for the project. Results are as follows.

Sanitary Line A segment between MH C-4 & A-1
Line held at 4psi for 7:34 with no drop
Test Passed

Line A segment between MH A-1 & A-2
Line held at 4psi for 9:02 with no drop
Test Passed

Line B segment between existing MH A-11 & B-1
Line held at 4psi for 7:34 with no drop
Test Passed

Line B segment between B-1 & B-2
Line held at 4psi for 8:52 with no drop
Test Passed

Air testing of both sanitary sewer lines passed.

Comments: