CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872

Address:

Comments:

This work has been inspected a corrective actions have been co	· ·		-
Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Mandrel	John DiMauro	Passed	Thursday, June 18, 2020
Informational: 1 Misc	John DiMauro 06/18/2020 3:03 PM I verified that the correct mandrel was used for the test according to the City Of LS Design and Construction Manual. I observed the mandrel pull through both sanitary lines A & B with no deflection.		
	Test Passed		