

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201270
Address: 200 NE MISSOURI RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, July 07, 2020

Corrective Action Required:

1	Misc	-Provide AC ratings at utility PV disconnect per revised plan. Plan shows incorrect 240V one phase ratings -Provide rapid shutdown labeling at utility PV disconnect per plan -Secure rooftop ent raceway -Provide DC ratings at inverters; provide other required labels per plan; label DC raceways per plan -Bond array modules. Check all -Protect all penetrations of fire-rated walls and ceiling
---	------	--

Comments: