

PLANS REVIEW CONDITIONS

| | | | |
|---|------------------------------|---------------------------|---------------|
| Permit No: | PRCOM20200307 | Date: | July 07, 2020 |
| Project Title: | THE SUMMIT CHURCH - ADDITION | Applicant: | |
| Location: | | | |
| 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081 | | ALPHA FIRE PROTECTION LLC | |
| Type of Work: | | 1510 W GEOSPACE DR | |
| Occupancy Group: | A-3 | INDEPENDENCE, MO 64056 | |
| Description: | ADDITION TO CHURCH FOR | | |
| OFFICE AND CHAPEL USE | | Primary: (816) 257-2260 | |
| Construction Type: | Type IIB (Unprotected) | | |
| Map Page: | 194B | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. Call (816)969-1300 to schedule a hydrostatic test.

2. (Informational Purposes)
Current annual inspection tag needed on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.