## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20200096

Address: 2313 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Michael Harkins Failed Tuesday, July 07, 2020

Residential

Corrective Action Required:

1 Misc - PROVIDE SOLID SECURITY BLOCKING EXTERIOR DOORS -

- TIGHTEN ANCHOR BOLTS BASEMENT -

- PROVIDE ANCHOR BOLT WITHIN 12" OF PLATE BREAK BED # 4 -

- PROVIDE LIB PER PLAN HALLWAY @ LAUNDRY -

- PFH PORTAL FRAME GARAGE PER PLAN PROVIDE 5/8 ANCHOR BOLTS W/

**SQUARE WASHERS -**

SECURE ALL BATH EXHAUST WITH METALLIC TAPE -

- COMPLETE HVAC BASEMENT -

**Comments:**