

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191733
Address: 1313 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, July 08, 2020

Corrective Action Required:

1	Misc	-Screw in the rear exterior door embedded brace into studs **Take a look at the deck door frame. There are 4 screw holes that are already pre-drilled: one hole 12" above and 12" below the strike plate and two behind the strike plate. Please use 3" screws and screw into these holes to secure the embedded brace into the jamb stud. Take a picture and send it to me.
---	------	---

Comments: