

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172523  
Address: 245 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Wednesday, July 08, 2020

Corrective Action Required:

1	Misc	- PROVIDE PUUTY PADS THROUGHOUT - - 301 STRAP TOP PLATE LIVING ROOM - - 311 STRAP TOP PLATE LIVING ROOM - - STRAP TOP PLATE CORRIDOR - - FIRE BLOCK DEAD SPACE AT DECK DOORS MIDDLE UNITS - - 304 FIRE COLLAR DEAD SPACE AT TUB -
---	------	--

Comments: