

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200989
Address: 2927 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, July 08, 2020

Corrective Action Required:

1	Misc	- Seal all top plate penetrations - garage, basement - H2.5 strap missing master closet - Secure and protect pex at showers per manufacturer listing - Support DWV every 48" o.c. - Truss hangers per plan - Nail dbl/triple truss per plans - Remove back porch lid so that both truss hangers can be inspected - Install missing window in kitchen - EC#2 Hold down per plans - Fireblock all traps and tubs, no light through - Anchor all columns in basement - Fireblock every 10' vertical between framing and foundation wall in basement
---	------	--

Comments: