

7/8/20

Joe Frogge  
Codes Administration  
220 SE Green Street  
Lee's Summit, MO 64063

Re: Re-submittal  
'Z' Hair Academy  
232 NW Oldham Parkway  
PRCOM20201750

Dear Joe:

Attached is an electronic copy of the revised plans. My response comment numbers below correspond to your review comment numbers.

#### BUILDING PLAN REVIEW

1. FRP has been noted to be installed on the wall behind the mop sink
2. Condensing unit location is shown. The unit is only about 2.5' tall and 3' wide. Given the location near the center of the roof, it cannot be seen from the ground at the streets to the west and east. None of the other existing roof mounted units at the center have any special screening. A duplex outlet has been noted to be provided at the condensing unit. Fresh air information has been added to the mechanical sheet.

#### LICENSED CONTRACTORS

1. Understood

#### FIRE PLAN REVIEW

1. Understood
2. Understood
3. Understood

Sincerely,



Jeff Schroeder, AIA, President  
Herman A. Scharhag Co., Architects