

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Robb Popp	Partial	Thursday, July 09, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	ROOF DRAINS: 8" WEST SIDE TO MAIN DRAIN; 6 LINE-10; AMBULANCE BAY 3" ROOF DRAIN TO EXTERIOR.  ACID WASTE: AMBULANCE BAY, EMERGENCY SHOWER DRAIN TO EXTERIOR; SANITARY: 4" STACK AND 1B118, 114-117; M LINE 1-3; TOILET RM 94 FROM PATIENT RM 1B096-1B107; 1B105 FROM PATIENT RM 111 TO SOIL RM 104 RM B093-B096 RM 1B109-1B113 MAIN FROM COLUMN LINE 9 TO LINE 10 RM 078, 081, 083, 085, 086, 087, 089, 091
---	--	--

Comments: