

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20201270  
Address: 200 NE MISSOURI RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, July 09, 2020

Corrective Action Required:

1	Misc	-Provide AC ratings at utility PV disconnect per revised plan. Plan shows incorrect 240V one phase ratings -Provide rapid shutdown labeling at utility PV disconnect per plan **See NEC 690.56 for labeling requirement -Provide DC ratings at inverters; provide other required labels per plan; label DC raceways per plan -Protect all penetrations of fire-rated walls and ceiling
---	------	---

**Comments:**