

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193519
Address: 1504 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 10, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Protect and support pex at showers per manufacturer listing- Seal all bottom plate penetrations - 1st floor bed- Seal penetrations at 1st/2nd floor stairs- Truss bracing per plans 2nd floor- Truss hangers per plan- Flashing at garage trim, 2nd floor back window |
|---|------|--|

Comments: