

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193513
Address: 1508 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 10, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Properly Fireblock all tub traps, no light through- Secure and protect pex at showers per listed product- Secure pex at all chase locations per listed product - kitchen dining, garage entry- Support DWV every 48" o.c., traps are not considered support- Garage PFH per plans- Truss hangers per plans- Connect top plates at top stair landing at 2x6 to 2x4 wall- Provide engineered fix of double girder truss on bearing wall at bedroom #2 and hallway, not supported at ends- Protection plate at radon 1st floor, 2nd floor laundry DWV- Solid block above lvl living room, kitchen |
|---|------|---|

Comments: