

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201270
Address: 200 NE MISSOURI RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Friday, July 10, 2020

Corrective Action Required:

1	Misc	-Provide rapid shutdown labeling at utility PV disconnect per plan **one within 3 ft of PV switch and service disconnect -Provide required label at combiner panel per plan -Protect all penetrations of fire-rated walls and ceiling
---	------	---

Comments: