

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200989
Address: 2927 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 10, 2020

Corrective Action Required:

1	Misc	- Secure and protect pex at showers per manufacturer listing - secure pex to support in bath #2 - Nail dbl truss per plans- above master bed/bath/closet - Install missing window in kitchen - Per contractor currently on backorder with manufacturer
---	------	--

Comments: