

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193472
Address: 1243 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, July 10, 2020

Corrective Action Required:

1	Misc	Final Codes- -install mirror in restroom. -install vertical grab bar at the correct height off the floor and off the rear wall. see ANSI A 117.1 code. --install GFCI at the outlet left if sink, all outlets within 6ft of sink needs to be GFCI. -- secure MC cable in Furnace room. Fire Dept-- provide emergency contact INFO at next inspection -- provide fire extinguisher --add exit sign to inside the office area over the door to the foyer. Reason - from the office side the exit sign over the front door is not visible.
---	------	---

Comments: