

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200613
Address: 2939 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 10, 2020

Corrective Action Required:

1	Misc	- UFER ground required - Color code ufer ground - Remove green panel bonding screw from sub panel
---	------	---

Comments: