

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20192761
Address: 4704 NE SARATOGA CT, LEES SUMMIT, MO 64064
Inspected On: Friday, July 10, 2020
Inspected By: Khanh Nguyen
Expiration Date: 8/10/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Friday, July 10, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -Lower water meter to grade. Make sure the meter to lid distance is 14"-18"
**Grading around the meter must be per plot plan. Lower the meter down to final grade
-Install the sewer tracer wire and port |
|---|------|---|