

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20193544	Date:	July 13, 2020
Project Title:	DCI - LEE'S SUMMIT	Applicant:	
Location:			
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	B	KANSAS CITY, MO 64116	
Description:	NEW DIALYSIS CLINIC BUILDING	Primary: (913) 888-0647	
WITH CANOPY			
Construction Type:	Type VB (Unprotected)		
Map Page:	194H		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a water flow.

2. (Informational Purposes)

Update records showing NFPA 13 2016 Edition

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.