

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193347
Address: 2021 NE BLUESTONE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, July 13, 2020

Corrective Action Required:

1	Misc	-Final grade, sod, downspout and sump pump extensions -Seal exterior electrical outlet. Box must recess no more than 1/4" behind brick wall -Shim gaps under deck joists at hanger support -Provide min six inches of clearance from storage space to ceiling luminaire in rear bedroom closet -Provide AFCI protection for dishwasher outlet -Anchor basement column at stair
---	------	---

Comments: