

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200127
Address: 2931 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, July 13, 2020

Corrective Action Required:

1	Misc	- Garage PFH per plans - Tighten all anchor bolts in garage - Protect and secure pex at showers per manufacturer listing - Metallic tape at bath fan exhaust connection - Support DWV every 48" o.c. - Truss hangers per plan in garage
---	------	---

Comments: