CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500 NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
DE - Curb	New/Replacement	Ronald Paynter	Partial	Monday, July 13, 2020	
Informational:					
1	Misc	Brad's crew from JK Concrete poured 160 cubic yards of KCMMB mix for curbing on Shamrock, Grady and Joshua. Mike from Geiger and Caleb from KC Testing were also present for the pour. We were steady at 6.5 air and 1 inch slump during random testing. They still need to form and finish the curb inlets. RP 6-18-20			
Informational:					
2	Misc		ete is forming up curb inlet ance of weather, they fill b		
Informational:					
3	Misc	Redford Construction still	ete set and poured all curb needs to set lids on Grady ed. The total distance for th	and Joshua before those	
Informational:					
4	Misc	Brad's crew formed and p Grady. RP 6-23-20	oured the remaining curb in	nlets on Shamrock and	
Informational:					
5	Misc	Brad's crew formed curbs being too hot. RP 7-7-20	on half of Ambersham. The	ey stopped due to it	
Informational:					

6	Misc	Brad's crew finished up on the part of Ambersham that was ready along with some of O'Brien. The also formed and poured 1 curb inlet before it too hot to work again. RP 7-8-20
Informatio	onal:	
7	Misc	Brad's crew laid curbing on Killarney and Ambersham where it connects to the older section. They still have a small portion of Ambersham to finish along with all the curb inlets. RP 7-10-20
Informatio	onal:	
8	Misc	Brad's crew finished pouring curbing for O'Brien, Ambersham and Killarney. RP 7-13-20

Comments: