

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193631
Address: 3020 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, July 14, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Terminate and complete exterior lighting at garage- Hood required at cooktop in kitchen- Fire/Co detector(s) required outside 1st floor bedroom vicinity- Garage door must be self closing- Cover plates at all receptacles- No access to jacuzzi tub motor, access panel in water closet is on opposite end of tub with motor- Dishwasher GFCI protection- Terminate or removed bundled Romex hanging in E corner of basement- Seal all penetrations in siding- No current at GFCI receptacle at front porch to test |
|---|------|--|

Comments: