

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193016
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary - Material Verification	Ronald Paynter	Failed	Tuesday, July 14, 2020

Corrective Action Required:

1	Misc	Manholes were manufactured by Forterra. They have the correct steps. They delivered the stamped STORM lids instead of the stamped SEWER lids. Sanitary pipe SDR26 is manufactured by Pipe Life Jetstream. RP 7-14-20
---	------	---

Comments: