

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Wednesday, July 15, 2020

Corrective Action Required:
2 FOURTH FLOOR AREA"E"- UNITS-(2 far south not ready)
Section E phase 1
439,440,461,441,442,459-ok
460- washer box 5 side.
Need Clarification on Egress window opening.
Install 5 sided box for dryer boxes.

Corrective Action Required:
3 THIRD FLOOR Section "E"
345-Ok
344-Ok
343- shower valve water lines brought down into 5side box.
342-ok
361-ok
362-5 side washer box.
363-BDL wall at both bedrooms fire stop between floors. Puddy pad corridor outlet.
341-ok
364-
340-hold down living room wall.
Mid supports are plumbing south units.

Comments: