

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192576
Address: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, July 15, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - SECURE CONDUIT AT GATE -
- ALL RESTROOM REAR GRAB BARS 6" MAX -
- RESTROOM SIGNS SHALL BE WALL MOUNTED -
- PROVIDE SIGNAGE POOL EQUIPMENT ROOM -
- SECURE WATER LINE & EXTEND TO FLOOR DRAIN IN POOL EQUIPMENT ROOM
-
- PROVIDE MAX 2" FENCE TO LANDSCAPING NEAR SLIDE -
- SECURE A/C WHIP -
- PROVIDE SPLIT BOLT BARE COPPER & GREEN GROUND POOL EQUIPMENT ROOM -
- POOL FENCE OPENING NOT MORE THAN 1/2" AT GATE -
- PROVIDE 42" GUARDRAIL AT SLIDE -
- PROVIDE HANDRAIL SLIDE STEPS -
- NO FOOTING INSPECTIONS FOR MONUMENT SIGNS - |
|---|------|--|

Comments: