

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200993
Address: 3013 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, July 15, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Seal all top plate penetrations - basement- Protect and support pex at showers/tubs per manufacturer listing- Address cut and notched truss in garage at end of beam, hanger also missing- Remove front porch lid to allow inspection of truss hangers- Fireblock vertical to horizontal at basement fir down |
|---|------|---|

Comments: