

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201062
Address: 1804 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Robb Popp	Not Ready	Friday, July 17, 2020

Corrective Action Required:

1	Miscellaneous Correction	****NOT READY**** -THIS LIST IS INCOMPLETE- -NO SERVICE PANEL, NO SERVICE CABLE -LAND ALL ELECTRICAL IN SERVICE PANEL -PROTECT ALL NM WIRES WHERE WITHIN 1 1/4' OF FACE OF STUD -PROVIDE 20 AMP CIRCUIT IN GARAGE PER CODE
---	--------------------------	---

Comments: