

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20201058
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	John Jackson	Partial	Friday, July 17, 2020

Informational:	
1 Misc	2" Blue poly domestic water line was layed approximately 100' on 6-30-20 and 180' 7-1-20. Its layed just to the outside of the Fire Line.
Informational:	
2 Misc	7-7-20 Tuesday continued to run 2" Blue poly domestic water line approximately 100' .
Informational:	
3 Misc	7/7/20 Friday connected the 2" Blue poly domestic line to existing copper line.

Comments: