

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200534
Address: 3201 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, July 20, 2020

Corrective Action Required:

1	Misc	- SHIELD ELECTRICAL BOX IN PLENUM IN HALL AT MASTER - - PROVIDE JOIST HANGERS ABOVE SUMP PUMP - - SEAL BORES IN TOP & BOTTOM PLATE AT MASTER SHOWER - - BED # 2 PROVIDE (3) 2 X 12 FOR ROOF SUPPORT PER PLAN - - PROVIDE PFH PORTAL FRAMING GARAGE DOORS PER PLAN DETAIL 1 S3.0 - - SHEATH GARAGE FACE OF REAR WALL PER FRAMING NOTE #1 - - ADDRESS RAFTERS LANDING ON BLOCKS THROUGHOUT -
---	------	--

Comments: