

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192138  
Address: 1517 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                 |
|-------------------------------------------------|--------------------|----------|-----------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Monday, July 20, 2020 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                                                                                                     |
|---|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | <ul style="list-style-type: none"><li>- Resolve outstanding items from all rough inspection</li><li>- Switch plate cover at furnace switch</li><li>- High / low vent for furnace combustion air required</li><li>- Secure AC disconnect electrical whip to house from laying across grade</li></ul> |
|---|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**