

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192138
Address: 1517 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, July 21, 2020

Corrective Action Required:

1	Misc	- Switch plate cover at furnace switch - High / low vent for furnace combustion air required - Secure AC disconnect electrical whip to house from laying across grade - Gas meter is buried
---	------	---

Comments: