

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200509  
Address: 1041 NE SAM WALTON LN, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	Mark Harding	Failed	Tuesday, July 21, 2020

**Corrective Action Required:**

1	Misc	no access - provide approved access to roof for inspection of gas line and 2 new RTU's. 4th inspection fee required.  Failed-MARK HARDING 07/21/2020 9:40 AM provide approved ladder to roof top, tie off , provide ladder over side to roof deck. paint gas line to RTU's. Label RTU'Sfor space "D" 1 & 2 or A&B . 4 Re-inspection fee due
---	------	---

**Comments:**