

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200117  
Address: 1816 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Tuesday, July 21, 2020

Informational:

1	Miscellaneous Correction	-portal framing hold down and nailing pattern inspected-
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	***DO NOT INSULATE***  -SEAL UPWARD PENETRATION AT TOP PLATE IN MASTER BATH BY CLOSET
---	--------------------------	---

**Comments:**