

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20180411  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John DiMauro	Failed	Tuesday, July 21, 2020

Corrective Action Required:

2	PW-Erosion and Sediment Control	Your project is in violation of the Erosion and Sediment control policy.  After the heavy rain even there are a number of inlet protection devices that have failed. They are filled with silt and construction debris and allowing silt and debris to bypass and collect into the inlets.  Please make corrections to the devices asap.
---	---------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**