DO NOT CUT, DRILL, NOTCH, OR OTHERWISE DAMAGE TRUSSES. Contact your BFS Representative for assistance PRIOR TO modifying any truss. Espanol - (NO CORTE, PERFORE, HAGA MUESCAS O DANE DE CUALQUIER OTRA MANERA LAS TRUSSES (CERCHAS DE

MADERA). Contacte a su representante de BFS para asistencia ANTES de realizar cualquier modification.)

1. This Truss Placement Diagram is intended to serve as a guide for truss installation. This Diagram has been prepared by a Truss Technician and is not

an engineered drawing.
2. The responsibilities of the Owner, Building Designer, Contractor, Truss Designer, and Truss Manufacturer shall be as defined by the TPI 1 National Standard.

3. The wood components shown on this diagram are to be used in dry service (moisture content<19%) and non-toxic environmental applications. The metal plates and hangers are galvanized to the G60 Standard unless noted

4. Refer to the Truss Design Drawings for specific

information about each individual truss design. 5. The Truss Technician shall provide Truss-to-Truss Connection Requirements. Any special or other connection shall be the responsibility of the

Building Designer.
6. The Truss Placement Diagram and Truss Design Drawings are the property of Builders FirstSource and may not be reused or reproduced in part or in total under any circumstances without prior written authorization

7. In some cases, field framing may be required to achieve the final appearance shown on the Construction Documents

8. Field framing, including valley rafters, installed over roof trusses shall have a knee brace from the rafter to the truss top chord at intervals of 48" on center (O.C.) or less. Stagger knee braces from adjacent rafters such that the load is distributed uniformly over multiple truss locations and not concentrated at one location or along one truss.

9. Truss Top Chords shall be fully sheathed or have lateral bracing (purlins) spaced at 24" O.C. or less. Truss Bottom Chord Bracing shall not exceed the maximum shown on the Truss Design Drawing. Field framed bottom chord floor or ceiling attachments shall be spaced at 24" O.C. or less. Proper Bracing prevents buckling of individual truss members due to design loads.

10. This Placement Diagram is based upon the supporting structure being structurally adequate, dimensionally correct, square, plumb, and level to adequately support the trusses. The foundation design, structural member sizing, load transfer, bearing conditions, and the structure's compliance with the applicable building code are the responsibility of the Owner, Building Designer, and

11. If Piggyback Trusses are included in this project, refer to the Mitek Piggyback Connection Detail applicable for the project details and wind load

category.
12. The Contractor shall follow the SBCA TTB Partition Separation Prevention and Solutions for truss attachment to non-load bearing walls and carefully complete these details to avoid gypsum wall board related issues. WARNING:

TRUSSES MUST BE BRACED DURING INSTALLATION. FAILURE TO DO SO MAY RESULT IN INJURY OR DEATH. Espanol -(TRUSSES (CERCHAS) DEBERAN TENER UN SOPORTE DURANTE LA INSTALACION. NO HACERLO PODRIA RESULTAR EN LESIONES O MUERTE.)

 Trusses shall be installed in a safe manner meeting all code, local, OSHA, TPI, and BCSI Specifications. Failure to follow these specifications may result in injury or death.

2. Buildings under construction are vulnerable to high winds and present a possible safety hazard. The Contractor is responsible for recognizing adverse weather conditions and shall take

appropriate action to prevent injury or death.
3. BCSI INSTRUCTIONS SHALL BE FOLLOWED: BCSI-B1 = Safe Truss Handling and Inst

BCSI-B2 = Installation and Temporary Restraint BCSI-B3 = Permanent Restraint

BCSI-B4 = Safe Construction Loading BCSI-B5 = Truss Damage and Modification

Guidelines BCSI-B7 = Floor Truss Installation BCSI-B8 = Toe-Nailed Connections

BCSI-B9 = Multi-Ply Girders

BCSI-B10 = Post Frame Truss Installation

BCSI-B11 = Fall Protection

4. Follow TPI Requirements for Long Span Trusses

## RELEASE FOR CONSTRUCTION **AS NOTED ON PLANS REVIEW CODES ADMINISTRATION** LEE'S SUMMIT, MISSOURI

## 07/21/2020

HNGR	QTY	CARRIED MBR
HUS26	3	A8,A9,J18
LTHJA26	2	CJ6,CJ7
H2.5A	120	ALL ROOF TRUSSES TO BE CONNECTED TO THE TOP PLATE WITH H2.5A HURRICAN CLIPS AND/OR ANY GIRDER UPLIFT OR SPECIAL UPLIFT NOTED WITH APPROPRIATE CONNECTOR.

FRONT TO BACK PITCH: 5/12 SOFFIT DESIGNED FOR 12"

HEEL: 7-3/4"

SIDE TO SIDE PITCH: 5/12 SOFFIT DESIGNED FOR 12"

HEEL: 7-3/4"

WALL HEIGHT: 9' 1-1/8" **EXTERIOR WALLS 2X4** 

VAULTS: 3/12

BOX COFFERS: 1' ABOVE PLATE HEIGHT

SEE LAYOUT FOR INFO DIFFERENT FROM ABOVE STANDARD

Roof Plane Hip Lines, 177.52 Horizontal Overhang Lines, 223 Raked Overhang Lines,0 Ridge Lines1,28 Roof Area, 2828, 3 Valley Lines,54.41

> RESIDENTIAL ENGINEERING SERVICES, LLC SHOP DRAWING / SUBMITTAL REVIEW

## **APPROVED**

SUBMITTAL WAS REVIEWED FOR DESIGN CONFORMITY AND GENERAL CONFORMANCE TO CONTRACT DOCUMENTS ONLY. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRING AND CORRELATING DIMENSIONS AT JOBSITE FOR TOLERANCE, CLEARANCE, QUANTITIES, **FABRICATION PROCESSES AND** TECHNIQUES OF CONSTRUCTION, COORDINATION OF

HIS OR HER WORK WITH OTHER TRADES AND FULL COMPLIANCE WITH CONTRACT DOCUMENTS.

NGINEER NG SERVICES, LLC

TRUSS LAYOUT

1 of 1

ROOF

PAGE

**DESIGN LOADS:** 

25 PSF TCLL

10 PSF TCDL

10 PSF BCDL

IGNED AND
O BE APPLIED
O AT NO TIME
LIED TO THE
TIONS ONLY
CAPABLE OF

WWW.BLDR.COM

S

 $\overline{\Phi}$ 

Build

-irstSource

