

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182387
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|-------------------------|
| Occupancy Inspection - Codes Commercial | Michael Harkins | Failed | Thursday, July 23, 2020 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | - INSTALL DISHWASHER KITCHEN with hammer arrestor. - - DISHWASHER DISCHARGE PIPE OR TUBING SHALL RISE TO UNDERSIDE OF THE COUNTER AND BE FASTENED OR OTHERWISE HELD IN THAT POSITION BEFORE CONNECTING TO THE HEAD OF FOOD WASTE DISPOSER OR WYE IN SINK TAILPIECE - |
|---|------|---|

Comments: