CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192215

Address: 3340 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Thursday, July 23, 2020

Residential

Corrective Action Required:

1 Miscellaneous

-PROVIDE (2) 3" SCREWS AT EACH HINGE AND STRIKE PLATE IN EXTERIOR

Correction DOORS PER SEC.7-1408.1 & 7-1408.2

-EXTERIOR LIGHT FIXTURES LESS THAN 8' IN HEIGHT TO BE MANUFACTURED TO

BE "NOT READILY ACCESSIBLE" PER SEC.7-14.09

-PROVIDE SELF CLOSING HINGES AT GARAGE DOOR PER CODE

-RECEPTACLE CIRCUIT IN GARAGE TO BE 20 AMP AND SERVE ONLY GARAGE

PER CODE

-BREAK OFF SET SCREW IN ANTI-SYPHON DEVICE IN BASEMENT

-PROVIDE LOCKOUT DEVICE ON FURNACE BREAKER

-PROVIDE HAMMER ARRESTORS AT LAUNDRY

-ATTACH BALUSTERS IN STAIR RAILING

-SECURE WHIP AT AC UNIT

-MISSING NAILS IN POST BASES AT DECK

-PROVIDE JOIST HANGER AT DOUBLE JOIST AT DECK

-PROVIDE JOIST HANGERS AT ALL JOISTS OVER 4' AT DECK

-PROVIDE ANGEL BRACKET OR HANGER ON END JOISTS AT HOUSE OFFSET

-PROVIDE ENGINEERED CONNECTION AT TRIPLE BEAM TO POSTS

-BOLT RIM BOARD TO POSTS

Comments: