

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200388
Address: 4725 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------|--------------|----------|-----------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Friday, July 24, 2020 |

Corrective Action Required:

1 Misc

FRAMING:

- Fb foyer wall from roof
- Support rafters to 2x10 purlin with hangers or blocking underneath rafters
- Have engineer address non-continuous 2x4 studs in exterior wall exceeding 12 ft in garage and front bedroom
- Fb fireplace space from roof.
- Fb double stud wall in basement vertically every ten ft or less

**OK TO INSULATE

Comments: