## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20191872 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	on:	Inspector:	Outcome:	Date:
DE - Stre	et - Proof Roll	John DiMauro	Partial	Friday, July 24, 2020
Corrective Action Required:				
1	Misc	I observed the proof roll for the Portland Cement treated sub grade prior to the aggregate going in. There were a number of areas with deflection. The sub grade still needs more time to cure out.		
Informational:				
2	Misc	I observed the proof roll for the Portland Cement treated sub grade prior to the aggregate going in. The roll test passed with no deflection. The crew plans to install the base rock layer next week.		

Comments: