

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201648  
Address: 161 NW CARSON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Michael Harkins	Passed	Monday, July 27, 2020

Informational:  
1 Misc - 3RD PARTY FOOTING SIGNED & STAMPED BY DAVID P AINSWORTH -  
- COMMENTS: UFER ROD LOCATED IN REAR FOUNDATION WALL ABOUT 22'  
SOUTHEAST OF SOUTHWEST CORNER -

**Comments:**