

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRLD20190454
Address: 300 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------------------|----------------|----------|-----------------------|
| DE - Erosion Sediment Control (ESC) Inspection | Ronald Paynter | Failed | Monday, July 27, 2020 |

Corrective Action Required:

| | | |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | Phase 2 erosion controls need to be installed. Roadways need to be cleaned were silt has washed out into roadways. Gutter buddies on O'Brien, Ambersham and Killarney need concrete blocks placed behind them. RP 7-27-20 |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Comments: