

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200840
Address: 2914 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, July 27, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Maintain gravel filter on lot- Seal all floor penetrations between 1st floor and basement- Security blocking at front, back door, and basement door- Seal Fireblock in deadspace bedroom#2- EC#2 per plans and R602.10.7- Fireblock vertical horizontal at basement fir down and all beam webs in finished- Seal gaps in horizontal and vertical fireblocking in fir out walls- tighten Hold down at NE side of dining windows per plans |
|---|------|---|

Comments: