

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200113  
Address: 3125 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Monday, July 27, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Garage PFH portal framing per plans - 5/8" anchor bolt w/ 2"x2" x 3/16" washer</li><li>- Bed #2 - cont Simpson CS18 coil strap around top plate perimeter per plans ( email engineer letter to DevTech@cityofls.net to upload to permit )</li><li>- Security blocking at rear and basement door</li><li>- Tighten all anchor bolts in basement</li></ul>
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**