

PACKARD ENGINEERING

21021 Oak Drive

Belton, MO 64012

Phone: (816) 767-7222

Fax: (816) 767-8105

E-mail: dan@packardstructuralengineering.com

CLIENT Skip Hirst

Page R01

Date 6/10

JOB 2301 NE Independence

Job No. SKA20001


Lee's Summit, MO

Made By DJP


NEW O.H. Ror Opening

OPENING HEIGHT	ANGLE
10'	5" x 3 1/2" x 5/16"

NOTE: LEAVE EQUAL SECTION OF WALL PANEL BEYOND OPENING, TYP.




FIELD VERIFY 0'-8" WALL THICKNESS



SECTION @ JAMB OF R.O.

SCALE: NONE



PACKARD ENGINEERING

21021 Oak Drive

Belton, MO 64012

Phone: (816) 767-7222

Fax: (816) 767-8105

E-mail: dan@packardstructuralengineering.com

CLIENT Skip Hirst

Page R02


Date 6/20

JOB 2301 N.E. Independence
Lee's Summit, MO
NEW O.H. Door Opening

Job No. SHAR0001


Made By WP

OPENING WIDTH	ANGLE
10'	5" x 3 1/2" x 5/16"



DETAIL @ HEAD TO JAMB JOINT

FIELD VERIFY 0'-8" WALL THICKNESS



SECTION @ HEAD OF R.O.

SCALE: NONE