

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193166
Address: 2626 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, July 28, 2020

Corrective Action Required:

1	Misc	- PROVIDE SECONDARY LOCK SLIDING GLASS DOOR DECK - - PROVIDE LOCK & SECONDARY LOCK SLIDING GLASS DOOR BASEMENT PATIO - - JUCUZZI TUB MASTER GFCI HOT NEUTRAL REVERSED- - PROVIDE HANDRAIL DECK STAIRWAY - - PROVIDE SUMP DISCHARGE PIPE 36" FROM FOUNDATION - - PROVIDE SOD & SPLASH BLOCKS -
---	------	--

Comments: